

January 22, 2024

**Attention:** Cecylia Garbacz  
TECHNICAL STANDARDS & SAFETY AUTHORITY  
345 CARLINGVIEW DRIVE  
TORONTO, ON M9W 6N9

The design submission, Tracking Number 2023-07007, Web Portal Number 2023-S4669, originally received on November 16, 2023 was surveyed and accepted for registration as follows:

**CRN :** 0C24903.52 **Accepted on:** January 22, 2024  
**Reg Type:** NEW DESIGN **Expiry Date:** November 14, 2033  
**Drawing No. :** Scope of Registration [24 August 2023] As Noted  
**Fitting type:** Descote Valves  
Design registered in the name of : DESCOTE S A

**The registration is conditional on your compliance with the following notes:**

- It is understood that the temperature range (minimum / maximum) of the materials used for construction specified in the scope of registration must be restricted to the material specifications and their temperature limits indicated in the design code ASME B31.3 & ASME B16.34 as per client confirmation email on Jan 03, 2024.  
- The pressure rating class designations shall be based on ASME B16.34 as specified in the scope of registration and the drawings.

As indicated on AB-41 Statutory Declaration or AB-351 Declaration of Conformity form and submitted documentation, the code of construction are ASME B31.3.

- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration or AB-351 Declaration of Conformity as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.

- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration or AB-351 Declaration of Conformity form.

- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency, and maintains a valid Certification of Authorization Permit if required by the jurisdiction where manufacturing takes place, until that date.

- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3360 or fax (780) 437-7787 or e-mail [Issa@absa.ca](mailto:Issa@absa.ca).

Sincerely,



ISSA, SAMIR, P. Eng.  
DOP Cert. No. D00009269



Technical Standards and Safety Authority  
 345 Carlingview Drive  
 Toronto, Ontario M9W 6N9  
 www.tssa.org

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



**STATUTORY DECLARATION**  
**Registration of Fittings**

I, Jean Pierre RICHER, President  
 (Name and Position, e.g. President, Plant Manager, Chief Engineer)

of descote, SAS.  
 (Name of Manufacturer)

Located at 9 Avenue Jean Jaures, 69320 Feyzin, France 0033472892500 0033472892525  
 (Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of ASME B31-3  
 (Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001 which has been verified by the following authority, Lloyd's Register

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:

Technical & Sales Documents for: Series 1500, 2020, 2100, 2200/2300, 2500, 3100, 4025, 7300 & 8000  
 (drawings, calculations, test reports, etc.)

Declared before me at \_\_\_\_\_ in the \_\_\_\_\_ of \_\_\_\_\_

the \_\_\_\_\_ day of \_\_\_\_\_ AD 20 \_\_\_\_\_.

Commissioner for Oaths:

\_\_\_\_\_  
 (Printed name)

\_\_\_\_\_  
 (Signature)

\_\_\_\_\_  
 (Signature of Declarer)

**FOR OFFICE USE ONLY**

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C

2023-07007 **ABSA**  
 SAFETY CODES ACT - PROVINCE OF ALBERTA  
 ACCEPTED: **OC24903.52**  
 See acceptance letter for conditions of registration  
 Date: 2024-01-22 By: **SAMIR, BSA, P. Eng**  
REG. 00000058

CRN: OC24903.52  
 Registered by: \_\_\_\_\_  
 Dated: 2024-01-22

CERTIFIÉ SINCÈRE ET VÉRIFIABLE PAR  
 Me Xavier Boulet notaire  
 associé à ECULLY (Rhône), la  
 signature de Jean Pierre RICHER  
 apposée ci-dessus  
 ECULLY, le 30 août 2023



**NOTE: This registration expires on: 2033-11-14**


\*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.

**Manufacturer name: descote s.a.s.**

24 August 2023

descote valves are in full compliance with design, dimensions, materials and service of ASME B31.3/ASME B16.34

Series	Description	Pattern	Size	Pressure class	Temperature mini/maxi	Wall thickness	Materials
<b>1500 series</b> (manual, actuated on-off, control)	Gland type globe valve	T-Pattern & 3-Way	3/8" to 12"	ANSI class 150 to 2500 lbs	-320°F to +1500°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625 - ASTM B462 UNS N08020 ASTM A216 Gr. WCB, WCC - ASTM A352 Gr. LCC, LC3 - ASTM A351 Gr. CF8M, CF3M, CF8, CF3 - ASTM A494 CW12MW, M35.1, CY40, CW6MC, CW6M, CW2M- A351 CN7M
<b>2020 series</b> (manual, actuated on-off, control)	Instrumentation bellows sealed globe valve	T-Pattern	1/8" to 1/2"	ANSI class 600 to 2500 lbs	-320°F to +1500°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625, N02200 - ASTM B462 UNS N08020
<b>2100 series - including 3100</b> (manual, actuated on-off, control)	Bellows sealed globe valve	T-Pattern , Angle & 3-Way	3/8" to 16"	ANSI class 150 to 2500 lbs	-320°F to +1500°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625 - ASTM B462 UNS N08020 ASTM A216 Gr. WCB, WCC - ASTM A352 Gr. LCC, LC3 - ASTM A351 Gr. CF8M, CF3M, CF8, CF3 - ASTM A494 CW12MW, M35.1, CY40, CW6MC, CW6M, CW2M- A351 CN7M
<b>2200/2300 series</b>	Double sealing device for storage tank	Angle	1" to 8"	ANSI class 150 to 600 lbs	-150°F to +750°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625 - ASTM B462 UNS N08020 ASTM A216 Gr. WCB, WCC - ASTM A352 Gr. LCC, LC3 - ASTM A351 Gr. CF8M, CF3M, CF8, CF3 - ASTM A494 CW12MW, M35.1, CY40, CW6MC, CW6M, CW2M- A351 CN7M
<b>2500 series - including 4025</b> (manual, actuated on-off, control)	Bellows sealed globe valve	T-Pattern	3/8" to 12"	ANSI class 150 to 2500 lbs	-320°F to +1500°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625 - ASTM B462 UNS N08020 ASTM A216 Gr. WCB, WCC - ASTM A352 Gr. LCC, LC3 - ASTM A351 Gr. CF8M, CF3M, CF8, CF3 - ASTM A494 CW12MW, M35.1, CY40, CW6MC, CW6M, CW2M- A351 CN7M
<b>7300 series</b>	Bellows sealed gate valve	T-Pattern	1/2" to 1"1/2"	ANSI class 300 to 800 lbs	-20°F to +500°F	According to ASME B31.3/ B16.34/API 602	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625, N02200 - ASTM B462 UNS N08020
<b>8000 Series</b>	Check valve	T-Pattern	3/8" to 10"	ANSI Class 150 to 2500 lbs	-320°F to +1500°F	According to ASME B31.3/ B16.34	ASTM A105 - ASTM A350 GR. LF2 , LF3 - ASTM A182 Gr. F316, F316L, F304, F304L - ASTM B564 UNS N10276, UNS N04400, UNS N06600, N06625 - ASTM B462 UNS N08020 ASTM A216 Gr. WCB, WCC - ASTM A352 Gr. LCC, LC3 - ASTM A351 Gr. CF8M, CF3M, CF8, CF3 - ASTM A494 CW12MW, M35.1, CY40, CW6MC, CW6M, CW2M- A351 CN7M



This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.